



Existing Water tank



Replace existing water storage tank (approx 5.2m diameter and 2.30m high). The new tank will be built at a location adjacent to the maintenance facility, and will be approx 6.2m diameter and 4.5m high (if circular) or 36m² x 3.5m (rectangular) with a capacity of at least 120m³ and be manufactured by Balmoral, CST Vulcan Tanks or approved other and constructed of flat galvanised panels. The construction method shall be from the roof down, with the construction carried out at ground level. A new reinforced concrete base shall be constructed to the tank manufacturer's specifications.

