

Information as follows:

8 BRUCE GROVE (ref: HGY/2022/2678 & HGY/2022/2677)			
COND. NUMBER	SUMMARY	CONDITION WORDING	RESPONSE
3 (condition replicated under same number in LBC)	Proposed Materials to Paving and Boundary	All proposed materials and finishes to paving and boundary treatment are to be approved by the Local Planning Authority either on site or through submission of on-site photos of the proposed materials.	London Yellow Stock sourced from London Reclaimed Brick Merchant 

			
--	--	--	---

			Resin-bonded gravel surfacing to be KBI Flexistone; colour 'Barnsley Solo' – see image below  NEW GRANITE SETTS To be 100 x 100 x 100 mm reclaimed natural split granite setts. To be supplied by CED Stone Group
--	--	--	---

--	--	--



NEW GROUND LEVEL LIGHTING

			EXL.1 Collingwood GL019 Ultra-low Glare  • 1W mini LED ground light, • 350mA/700mA input • Ref. GL019DMBL27 • Dims: 40mm dia, 150mm deep (with tube) • 2700K • 30° beam angle • 60 lumens • 60 lumen/watt • 25 lux @ 1m • 70,000hr lifespan • 7 year warranty • IP68, IK07 • Stainless steel • Class 3 • 1m fly-lead from factory (6mm OD) RECONSTITUTED STONE PIER CAPS
--	--	--	--

- Acanthus Cast Stone Ltd Wimsey Way, Somercotes, Derbyshire, DE55 4LS t: 01773 540 704



Pier caps

Concrete edging to Planter beds / resin bound gravel

			Travis Perkins Concrete Flat Top Path Edging EF 50mm x 200mm x 915mm   Indicates concrete edging only; all other materials as listed above
--	--	--	--

4	No excavation in Bin Area	Compliance condition: No excavation are permitted with the installation of a new bin area.	We confirm that there will be no excavation to the new bin area – the enclosure is to be fixed to the new surfacing
---	---------------------------	--	---