

Mr Serhan Senyurek
Se & Se Consultancy Ltd.
59a Turners Hill
Cheshunt
EN8 8NT

13 March 2024

**TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015
NOTICE OF PLANNING PERMISSION**

Case Reference HGY/2022/2062
Location 771, High Road, London, N17 8AH
Proposal Replacement of existing of extraction/ventilation system with
duct to the rear.
Received 18 July 2022

In pursuance of their powers under the above Act, the London Borough of Haringey as Local Planning Authority hereby PERMIT the above development received on the above date.

Title	Description	Date
771 High Road N17 8AH Extraction Report		7 August 2022
HR-1402		7 August 2022
HR-1402-Photographs		7 August 2022
Report 771 High Road N17 8AH		7 August 2022
HR-1402-BP		7 August 2022
HR-1402-OS		7 August 2022

Robbie McNaugher

Robbie McNaugher
Head of Development Management and Planning Enforcement
Planning Service

Conditions: (4)

- 1 The development to which this permission relates must be begun no later than three years from the date of this decision notice, failing which the permission shall be of no effect.

Reason: This condition is imposed by virtue of Section 91 of the Town and Country Planning Act 1990 and to prevent the accumulation of unimplemented planning permissions.

- 2 The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission.

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3 Noise emitted by all building services plant shall not exceed the existing measured lowest LA90(15min) background noise level at any time when all plant is in use. The noise emitted shall be measured or predicted at 1.0m from the facade of the nearest residential window or at 1.2m above any adjacent residential garden, terrace, balcony or patio. The equipment shall be serviced regularly in accordance with manufacturer's instructions and as necessary to ensure that the requirements of the condition are maintained. If at any time the plant is unable to comply with this Condition, it shall be switched off and not used again until it is able to comply.

- 4 All plant and equipment shall be supported on adequate proprietary anti-vibration mounts as necessary to prevent the structural transmission of vibration and regenerated noise within adjacent or adjoining premises, and these shall be so maintained thereafter. If at any time the plant is unable to comply with this Condition, it shall be switched off and not used again until it is able to comply.

Informatives:

INFORMATIVE: Land Ownership

The applicant is advised that this planning permission does not convey the right to enter onto or build on land not within his ownership.

INFORMATIVE: Hours of Construction Work

The applicant is advised that under the Control of Pollution Act 1974, construction work

which will be audible at the site boundary will be restricted to the following hours:-

8.00am - 6.00pm Monday to Friday

8.00am - 1.00pm Saturday

and not at all on Sundays and Bank Holidays.

- 1 You can find advice in regard to your rights of appeal at:
<https://www.gov.uk/appeal-planning-decision>.
- 2 This notice relates solely to a planning decision and does not purport to convey any approval or consent which may be required under the Building Regulations or any other statutory purpose.
If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal.
- 3 For more information about making a Building Regulations application, please contact Haringey Council Building Control Team by email building.control@haringey.gov.uk, telephone 020 8489 5504, or see our website at www.haringey.gov.uk/buildingcontrol.