

Mr Matt Humphreys
Clockwise
Greenside House
50 Station Road
London
N22 7DE

30 May 2024

**TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015
NOTICE OF PLANNING PERMISSION**

Case Reference HGY/2023/2654
Location 3 & 3a Curzon Road, Hornsey, N10 2RB
Proposal Erection of a three-storey rear extension, single storey ground floor extension, rear dormer extension and basement excavation with the reconfiguration of the existing two self-contained flats to form four self-contained flats comprising one 1-bedroom unit, two 2-bedroom units and one 3-bedroom unit.
Received 3 October 2023

In pursuance of their powers under the above Act, the London Borough of Haringey as Local Planning Authority hereby PERMIT the above development received on the above date.

Title	Description	Date
2203-P-4C – Proposed Loft Floor Plan (Revised)		10 April 2024
2203-P-7D – Proposed Rear Elevation (Revised)		10 April 2024
2203-P-1E – Proposed Basement Plan (Revised)		10 April 2024
2203-P-3G – Proposed First Floor Plan (Revised)		10 April 2024
2203-P- 5B – Proposed Roof Plan (Revised)		10 April 2024
2203-P-2K – Proposed Ground Floor Plan		29 April 2024
2203-P-9D – Proposed Section AA		29 April 2024
2203-P-10D – Proposed Section BB		29 April 2024
2203-P-8E – Proposed Side (South) Elevation		29 April 2024
2203-P-6E – Proposed Front Elevation		29 April 2024
2203-P-11D – Proposed Section CC		29 April 2024

Robbie McNaugher

Robbie McNaugher

Conditions: (11)

- 1** The development to which this permission relates must be begun no later than three years from the date of this decision notice, failing which the permission shall be of no effect.

Reason: This condition is imposed by virtue of Section 91 of the Town and Country Planning Act 1990 and to prevent the accumulation of unimplemented planning permissions.

- 2** The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission.

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3** Prior to the commencement of buildings works above grade, detailed drawings, including sections, material specification, including samples where necessary, to confirm the detailed design and materials of the:

- a) Detailed elevational treatment;
- b) Detailing of roof and dormer treatment;
- c) Windows and doors (including plan, elevation and section drawings indicating jamb, head, cill, reveal and surrounds of all external windows and doors at an appropriate scale, which shall include a recess of at least 115mm;
- d) Details of balustrading;
- e) Facing Brickwork: sample panels of proposed brickwork to be used showing the colour, texture, pointing, bond, mortar, and brickwork detailing shall be provided;
- f) Front boundary treatment; and
- g) Any other external materials to be used,

Shall be submitted to and approved in writing by the Local Planning Authority.

The development shall thereafter be carried out solely in accordance with the approved details.

Reason: To safeguard and enhance the visual amenities of the locality in compliance with Policies DM1, DM8 and DM9 of the Development Management Development Plan Document 2017. Management Development Plan Document 2017.

- 4 The proposed rooflight(s) hereby approved shall be 'Conservation style', flush with the roof plane in which they are installed and shall be maintained as such for the lifespan of the development.

Reason: In order to ensure a satisfactory appearance for the proposed development, to safeguard the visual amenity of neighbouring properties and to preserve the character and appearance of the Conservation Area, consistent with Policy HC1 of the London Plan 2021, Policy SP12 of the Haringey Local Plan 2017 and Policies DM1 and DM9 of The Development Management DPD 2017.

- 5 Details of the type and location of secure and covered cycle parking facilities shall be submitted to and approved in writing by the Local Planning Authority.

The development shall not be occupied until a minimum of 6 cycle parking spaces (2 for each flat) for users of the development, in accordance with the London Cycling Design Standards. Once agreed, the details shall be implemented as approved and retained/maintained as such thereafter.

Reason: To promote travel by sustainable modes of transport and to comply with the London Plan 2021 minimum cycle parking standards and the London Cycling Design Standards, policy T5 of the London Plan 2021, Policy SP7 of the Haringey Local Plan 2017 and to maximise the accessibility of the development.

- 6 A detailed scheme for the provision of refuse and waste storage and recycling facilities shall be submitted to and approved in writing by the Local Planning Authority. The approved scheme shall be implemented prior to the first occupation of the development and permanently retained thereafter.

Reason: In order to protect the amenities of the locality and to comply with Policy DM4 of The Development Management DPD 2017 and Policy D4 of the London Plan 2021.

- 7 The 1.7m high balcony screen shown along the side of the first floor shall be installed prior to the first use of the terrace area and shall there after be retained in perpetuity unless otherwise agreed in writing by the Planning Authority.

Reason: To avoid overlooking into the adjoining properties and to comply with Policy SP11 of the Haringey Local Plan 2017 and Policy DM1 of The Development Management DPD 2017.

No dwelling shall be occupied until a water butt of at least 120L internal

- 8 capacity has been installed to intercept rainwater draining from the front and rear roof slopes of the property. The water butt(s) shall be retained thereafter.

Reason: To reduce the risk of flooding and demand for water, increase the level of sustainability of the development and in line with Haringey Local Plan Policy SP5, DM21, DM24 and DM25.

- 9 Notwithstanding the information submitted with this application no development shall take place until a final Method Statement for the construction of the basement has been submitted to and approved in writing by the local planning authority.

The Method Statement shall demonstrate that the predicted Burland Scale at the time of the construction phase is no more than Burland Scale 1 in relation to neighbouring buildings/structures within the zone of influence. It shall include pre-commencement condition surveys of the adjoining building and the proposed systems of excavation support including any underpinning. The development thereafter shall be carried out in accordance with this approved methodology and detail.

The condition of nearby buildings shall be monitored throughout the construction process and works shall cease immediately if Burland Scale 1 damage is recorded.

Reason: To ensure that the proposed development would have no undue impact on the structural integrity of adjoining and neighbouring buildings, in accordance with Policy DM18 of the Haringey Development Management DPD 2017.

- 10 Works to implement the approved basement extension and lightwell shall not commence until such time as a suitably qualified chartered engineer with membership of the appropriate professional body has been appointed to inspect, approve and monitor the critical elements of both permanent and temporary basement construction works throughout their duration to ensure compliance with the design which has been checked and approved by a building control body. Details of the appointment and the appointee's responsibilities shall be submitted to and approved in writing by the Council prior to the commencement of development. Any subsequent change or reappointment shall be confirmed forthwith and retained for the duration of the construction works.

Reason: The details are considered to be material to the acceptability of the proposal, and for safeguarding the amenity of neighbouring residential properties in accordance with the policy DM18 of the Development Management DPD 2017.

- 11** No development shall commence until a scheme for the treatment of the surroundings of the proposed development including the timescale for the planting of trees and/or shrubs and appropriate hard landscaping has been submitted to and approved in writing by the Local Planning Authority. Any trees or plants, either existing or proposed, which, within a period of five years from the completion of the development die, are removed, become damaged or diseased shall be replaced in the next planting season with a similar size and species. The landscaping scheme, once implemented, is to be maintained and retained thereafter to the satisfaction of the Local Planning Authority.

Reason: In order to provide a suitable setting for the proposed development in the interests of visual amenity consistent with Policy D4 of the London Plan 2021, Policy SP11 of the Haringey Local Plan 2017 and Policy DM1 of The Development Management DPD 2017.

Informatives:

INFORMATIVE : Community Infrastructure Levy

The applicant is advised that the proposed development will be liable for the Mayor of London and Haringey CIL. Based on the information given on the plans, the Mayoral CIL charge will be £9,420.72 (136.0sqm x £69.27) and the Haringey CIL charge will be £57,453.20 (136.0sqm x £422.45 (Indexation included)). This will be collected by Haringey after/should the scheme is/be implemented and could be subject to surcharges for failure to assume liability, for failure to submit a commencement notice and/or for late payment, and subject to indexation in line with the construction costs index.

INFORMATIVE: The new development will require numbering. The applicant should contact the Local Land Charges at least six weeks before the development is occupied (tel. 020 8489 3472) to arrange for the allocation of a suitable address.

INFORMATIVE: Land Ownership

The applicant is advised that this planning permission does not convey the right to enter onto or build on land not within his ownership.

INFORMATIVE: Party Wall Act

The applicant's attention is drawn to the Party Wall Act 1996 which sets out requirements for notice to be given to relevant adjoining owners of intended works on a shared wall, on a boundary or if excavations are to be carried out near a neighbouring building.

INFORMATIVE: Hours of Construction Work

The applicant is advised that under the Control of Pollution Act 1974, construction work which will be audible at the site boundary will be restricted to the following hours:-

8.00am - 6.00pm Monday to Friday
8.00am - 1.00pm Saturday
and not at all on Sundays and Bank Holidays.

INFORMATIVE: Thames Water 1

Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website:

<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes>

INFORMATIVE: Thames Water 2

The proposed development is located within 15 metres of Thames Waters underground assets and as such, the development could cause the assets to fail if appropriate measures are not taken. Please read our guide 'working near our assets' to ensure your workings are in line with the necessary processes you need to follow if you're considering working above or near our pipes or other structures:

<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes> Should you require further information please contact Thames Water. Email: developer.services@thameswater.co.uk Phone: 0800 009 3921 (Monday to Friday, 8am to 5pm) Write to: Thames Water Developer Services, Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB

INFORMATIVE: Thames Water 3

As required by Building regulations part H paragraph 2.36, Thames Water requests that the Applicant should incorporate within their proposal, protection to the property to prevent sewage flooding, by installing a positive pumped device (or equivalent reflecting technological advances), on the assumption that the sewerage network may surcharge to ground level during storm conditions. If as part of the basement development there is a proposal to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing trade.effluent@thameswater.co.uk. Application forms should be completed online via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

INFORMATIVE: Thames Water 4

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at thameswater.co.uk/buildingwater.

INFORMATIVE: Thames Water 5

Thames Water will aim to provide customers with a minimum pressure of 10m head (approx. 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

- 1 You can find advice in regard to your rights of appeal at:
<https://www.gov.uk/appeal-planning-decision>.
- 2 This notice relates solely to a planning decision and does not purport to convey any approval or consent which may be required under the Building Regulations or any other statutory purpose.
If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal.
- 3 For more information about making a Building Regulations application, please contact Haringey Council Building Control Team by email building.control@haringey.gov.uk, telephone 020 8489 5504, or see our website at www.haringey.gov.uk/buildingcontrol.